

## **SECTION 608 COARSE AGGREGATE FOR FOUNDATION STABILIZATION AND SUBFOUNDATION BACKFILL**

**608.01 Description.** This work consists of furnishing and placing coarse aggregate for foundation stabilization and subfoundation backfill. This Section is to be used only when specified and authorized by the Engineer.

**608.02 Materials.** Coarse aggregate shall conform to the provisions of [Section 805](#) and to the grading requirements of [Section 813](#), Delaware No. 57.

**608.03 Construction Methods.** The bedding areas on which the coarse aggregate is to be placed will be approved by the Engineer.

Coarse aggregate shall be carefully placed and tamped to form a solid, unyielding mass with the exposed surface conforming to the form and dimensions shown on the Plans. Coarse aggregate shall be placed in locations where the exposed soil conditions are of such a nature and composition as to require the use of this material to achieve a satisfactory load-bearing condition.

**608.04 Method of Measurement.** The quantity of coarse aggregate will be measured as the actual weight placed and accepted. The weight will be calculated as specified in [Subsection 109.01](#).

**608.05 Basis of Payment.** The quantity of coarse aggregate will be paid for at the Contract unit price per ton (metric ton). Price and payment will constitute full compensation for furnishing, hauling, and placing the material and for all equipment, tools, labor, and incidentals required to complete the work.