

including caulking of joints.

Excavation to the face of the slab will be measured and paid for as provided in Section 203 - Excavation and Embankment. Excavation and backfill beyond the face of the slab will be considered incidental to the various contract items and no separate payment will be made.

Payment will be made under:

<u>Pay Item</u>	<u>Pay Unit</u>
611.16 Stone Slab for Backslope Protection Yard]	square meter [Square
611.17 Concrete Slab for Backslope Protection Yard]	square meter [Square

SECTION 612 - BITUMINOUS SEALING

612.01 Description This work shall consist of sealing bituminous mix surfaces with emulsified bituminous sealing compound of the specified color, applied at locations shown on the plans or designated.

612.02 Materials Bituminous material for sealing shall conform to the requirements of Emulsified Bituminous Sealing Compound, Section 702.12.

612.03 General The sealing compound shall be applied in two coats. The first coat shall be diluted by the addition of up to 50% water to a liquid consistency and applied with brooms or other approved methods at a rate of 1.25 L to 2.25 L [0.25 gal to 0.50 gal] of diluted sealer per square meter [square yard]. The second coat shall be diluted only to the extent necessary to obtain workability and applied at a rate of 1.1 L to 2.2 L [0.25 gal to 0.50 gal] of diluted sealer per square meter [square yard].

612.04 Method of Measurement Bituminous sealing will be measured by the square meter [square yard] of surface sealed measured parallel to the surface.

612.05 Basis of Payment The accepted quantities of bituminous sealing will be paid

for at the contract unit price per square meter [square yard] complete in place.

Payment will be made under:

<u>Pay Item</u>	<u>Pay Unit</u>
612.06 Bituminous Sealing-Black Yard]	square meter [Square Yard]

SECTION 613 - EROSION CONTROL BLANKETS

613.01 Description This work shall consist of furnishing and installing erosion control blankets on previously prepared areas in accordance with the manufacturer instructions or as called for on the plans or otherwise authorized.

Erosion control blankets shall be installed on critical slopes, shoulder berms, esplanade strips, curb sections, in ditches and drainage ways, and other previously prepared areas or as shown.

613.02 Materials Erosion control blanket shall conform to the requirements specified in the following Sections of Division 700 - Materials.

Erosion Control Blankets	717.061
Ground Anchors	717.063

613.03 Site Preparation The area for erosion control blankets shall be prepared as follows:

Soil must be loose or scarified, smoothly raked and free of stones, litter, and any abrupt ground surface roughness under the blanket.

613.04 Seeding All seed shall be sown before installing erosion control blankets. No loam will be required for Seeding, unless called for on plans or designated. Seeding, Method Number 2 will be used unless otherwise specified.

613.05 Installation On Slopes and in ditches, blankets shall be aligned in the