

405.04.03 Removal of existing structures for which no specific pay item is included in the Contract Documents will not be measured but the cost will be incidental to other pertinent items specified in the Contract Documents.

SECTION 406 — DRILLED HOLES IN EXISTING MASONRY

406.01 DESCRIPTION. This work shall consist of drilling holes in existing masonry for grouting of bars, bolts or anchorages, as specified in the Contract Documents or as directed by the Engineer.

406.02 MATERIALS.

Grout

902.11(c)

406.03 CONSTRUCTION. Holes shall be drilled only in the solid portion of the masonry, and are prohibited at points where cracks exist. Drilled holes shall be a minimum of 6 in. from the face of any masonry surface. The minimum size of dowel bars shall be No. 6. The holes shall be drilled at least 1/2 in. larger than the outside diameter of the insert to be grouted. Holes shall be cleaned and then filled two thirds full of grout. The insert shall be placed and allowed to set for 24 hours.

406.04 MEASUREMENT AND PAYMENT. Drilled Holes in Existing Masonry will be measured and paid for at the Contract unit price per linear foot of drilled holes. The payment will be full compensation for all material, labor, equipment, tools, and incidentals necessary to complete the work.

Inserts required for insertion in these holes will not be measured but the cost will be incidental to other pertinent items specified in the Contract Documents.

Drilled holes for which no specific pay item is included in the Contract Documents will not be measured but the cost will be incidental to the other pertinent items specified in the Contract Documents.

SECTIONS 407 — 409 RESERVED