

SECTION 1051—DOWNSPOUTING

1051.1 DESCRIPTION—This work is the furnishing and installation of downspouting.

1051.2 MATERIAL—As shown on the [Standard Drawings](#) and as follows:

- Fabricated Structural Steel—[Section 1105](#), galvanized as specified in [Section 1105.02\(s\)](#).
- Fiberglass Pipe and Fittings—[ASTM D 2996](#) RTRP with a 207 MPa (30,000 pounds per square inch), minimum short-time rupture strength hoop tensile stress. Use concrete gray as the final color of the reinforced fiberglass pipe, unless otherwise specified. Use a coating that protects the pipe from ultraviolet damage. Use manufacturer recommended paint and fittings.
- PVC Schedule 40 Pipe—[ASTM D 1785](#)

1051.3 CONSTRUCTION—Install downspouting, including the drain box, as indicated and as shown on the [Standard Drawings](#).

1051.4 MEASUREMENT AND PAYMENT—Lump Sum or Meter (Linear Foot)